









LEGEND:

- | | |
|---------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------|
|  | <p>LIGHTING FIXTURE WITH REFLECTOR, 2x40W, 230V, 50HZ FLUORESCENT LAMP, SURFACE MOUNTED(UNDER CEILING), I.H.=4~2.4.5m</p> |
|  | <p>DITTO BUT WALL MOUNTED, I.H.=3.0m</p> |
|  | <p>TUNEL TYPE LIGHTING FIXTURE WITH PROTECTIVE BASKET 1x18W, 230V, 50HZ, COMPACT FLUORESCENT LAMP, SURFACE MOUNTED(UNDER CEILING), I.H.=1.90~2.0m</p> |
|  | <p>DITTO BUT WALL MOUNTED, I.H.=1.70m</p> |
|  | <p>ON-OFF SWITCH, SINGLE POLE (SURFACE MOUNTED)</p> |
|  | <p>ON-OFF SWITCH DOUBLE POLE (SURFACE MOUNTED)</p> |
|  | <p>TWO WAY SWITCH, SINGLE POLE (SURFACE MOUNTED)</p> |
|  | <p>FREE STANDING OR SURFACE MOUNTED ELECTRICAL PANEL</p> |

NOTES & ABB.S:

- 1- LIGHTING'S CABLES ARE ACCORDING TO SLD OF DIST.PANEL & SHOULD BE RUN THROUGH GALVANIZED CONDUIT(Pg16)
- 2- SLD STANDS FOR SINGLE LINE DIAGRAM OFDIST. PANELS
- 3- CONTRACTOR SHOULD COORDINATE ANY INTERSECTION BETWEEN ELECTRICAL AND OTHER EQUIPMENTS OR OBSTACLES AND KEEP ENOUGH SPACE BETWEEN THEM.

FOR CONSTRUCTION

I S S U E S			
REV	DATE	COPY	ISSUED TO
99.12.13	S.C.	1	KERMAN BAREZ TIRE CO.
9	1400.10.14	1	KERMAN BAREZ TIRE CO.

[illegible]