



I S S U E S			
REV	DATE	COPY	ISSUED TO
99	12.13	S.C.	KERMAN BAREZ TIRE CO.
9	1403.10.14	1	KERMAN BAREZ TIRE CO.

LEGEND:

- 16A, SINGLE PHASE SOCKET OUTLET WITH EARTH CONTACT, SURFACE MOUNTED, I.H.=1.10m
- TELEPHONE OUTLET(Ru11), SURFACE MOUNTED, I.H.=1.10m
- 1x8W, 230V, AC, 50HZ, INDOOR EXIT LIGHT, SELF CONTAINED BATTERY BACK UP FOR 90min
- GALVANIZED TELEPHONE JUNCTION BOX, 10x10x5cm, I.H.=2.50~3.00

## NOTES &amp; ABB.S:

- 1- SOCKETS & EXIT LIGHTS CABLES ARE ACCORDING TO SLD OF DIST. PANEL & SHOULD BE RUN THROUGH GALVANIZED CONDUIT(Pg16)
- 2- SLD STANDS FOR SINGLE LINE DIAGRAM OF DIST. PANELS
- 3- TELEPHONE CABLE IS 5 PAIRS 42Y(st)2Y
- 4- CONTRACTOR SHOULD COORDINATE ANY INTERSECTION BETWEEN ELECTRICAL AND OTHER EQUIPMENTS OR OBSTACLES AND KEEP ENOUGH SPACE BETWEEN THEM.

FOR CONSTRUCTION

[illegible]