



CONTROL DIAGRAM

HVAC EQUIPMENT

LEGEND:

ROOM THERMOSTAT, ON/OFF TYPE, RANGE: 0-40°C,
220VAC, SIMILAR TO T631A1154 (HONEYWELL)
I.H.=130cm F.F.F., SET POINT=30°C

NOTES & ABB.S:

- 1- CABLES ARE ACCORDING TO SLD OF DIST. PANEL & SHOULD BE RUN THROUGH GALVANIZED CONDUIT(Pg16)
- 2- SLD STANDS FOR SINGLE LINE DIAGRAM OF DIST. PANELS
- 3- PANEL'S SPEC. ARE:
 - IP42
 - RAL 7035
 - INPUT & OUTPUT FROM BOTTOM
 - SURFACE MOUNTED PANEL

FOR CONSTRUCTION

[illegible]